

8.3.2.3 *Municipality of Tijuana/Private Owners* – Has the City of Tijuana (and private landowners/businesses) been apprised of the magnitude of impacts that could be created by the construction of the pipeline? Have the terms of agreement or easements for construction of the pipeline on private land been obtained?

9.5.2 *Wastewater Flows or Water Quality Parameters Outside Acceptable Limits* – Reiterate comments by SWRCB that no flows should be permitted to “bypass” untreated or partially treated sewage for any reason whatsoever.

9.5.5 *Pipe Break or Sewage Spill* - If repairs necessitate the shutting down of the facility, the excess raw sewage not treated at the SBIWTP should be diverted back to Mexico for treatment through their system. Under no circumstances should raw sewage be diverted through the SBOO.

Table 17-1 : *Bajagua Project Permits* – Please identify status of all permits listed

Thank you for the opportunity to review these RFP documents. We are making every effort to provide comments in a timely manner and will continue to do so as additional information is available.

Should you have any questions, please feel free to contact me at 619-5-424-7303 or 619-575-0550.

Sincerely,



Mayda C. Winter
Mayor Pro Tempore